

DATE Aug, 28, 1990

90321

Code

LOCATION Harrison N.E

Township

NW 1/4; Sec. 06; T. 4 S; R. 4 E

(circle one)		
Existing Home	New Home	Mobile Home
City Water	Cistern	Well
Subdivision <u>748</u>	Lot	
Basement w/plumbing fixtures Yes No		

lot # 14

HARRISON COUNTY HEALTH DEPT.
245 Atwood St. N. Wing
Corydon, Indiana
47112

Bosemet Dig
Prior to S.I. and
Health Department permit

APPLICATION FOR SITE SURVEY AND SEWAGE DISPOSAL PERMIT

Directions To Property Fay Sub. on Corydon - New Middleton
And Lot Size: rel

OWNER'S NAME AND MAILING ADDRESS

Richard Clip
150 W Cruise Loop Cory

INSTALLER'S NAME AND ADDRESS

John Roy Hall

TELEPHONE 738-3523

TELEPHONE _____

NO. OF BEDROOMS 3 NO. OF BATHS 2 AUTOMATIC WASHER YES NO _____

* HOME MUST BE STAKED OFF BEFORE SURVEY IS CONDUCTED
* DO NOT WRITE BELOW THIS LINE *

SOIL TYPE: clt + Foll (see above) Bm Dg

Estimated Depth To Bedrock or Water Table: _____

SPECIAL Recommendations: site extensively disturbed / locate septic tank
on the South of home / as high on lot as possible / stage lines of equal
length equally out of one #5 of #7 Dist. box / stage run lines as

SEPTIC TANK CAPACITY 1000 gal DRAINFIELD: TRENCH DEPTH 26 TRENCH WIDTH 36

TOTAL LENGTH OF TILELINE 330 linear ft USING RIVER GRAVEL (No Crushed Stone)

APPLICATION FOR PERMIT APPROVED NOT APPROVED _____

DATE: 8-29-1990 Fee Received: pd. SANITARIAN [Signature]

FINAL INSPECTION: approved Nov, 1990 DATE: [Signature] Sanitarian

NOTE: *Roy Hall pd. 30.00 fee by cash

THE SEWAGE DISPOSAL PERMIT MUST BE APPROVED BEFORE CONSTRUCTION IS STARTED
INSPECTION MUST BE MADE BEFORE THE LATERAL LINES ARE COVERED.
Call for inspection either the day before or between 8:00 and 9:00 in mornings, 738-3237. high on slope
The maximum length of any one trench is 100 feet.
Six (6) inches of gravel under lateral lines and two (2) inches above pipe. as possible /
Must be installed 50 feet or more from water supply lines.
Five (5) feet or more from property lines.
Distances between trenches — seven one-half (7 1/2) feet. may split system if
On the back draw a plot diagram showing the size and shape of the lot, location of utility buildings, desired
wells, roads, and/or streams within 100 feet of the disposal system, the location of the septic tank,
and the location of the drainage field. Approximate distances must be shown from the disposal system
to any proposed or existing water lines, wells, streams, and the lot lines.
If construction is not started within a period of one year, this permit is void.

WARNING: THIS PERMIT IN NO WAY GUARANTEES THE OPERATION OF THIS PRIVATE SEWAGE DISPOSAL SYSTEM. IT ONLY AFFIRMS THAT THE SYSTEM WAS INSTALLED TO PRESCRIBED STANDARDS.

